



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

MINOR SPILL REPORT TO EPD FAX 404 656-2453

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Saturday, January 21, 2017 3:00pm – 6:00pm

REPORT SUBMITTED: Tuesday, January 24, 2017

LOCATION OF MINOR SPILL: [2820 Pierce Drive S](#), MH ID 64565
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: The cause of this minor spill was hydraulic overload due to heavy rains in the MWA service area.

ESTIMATED VOLUME DISCHARGED: 3450 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Bowman Branch

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and affected area disinfected with lime.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Saturday, January 21, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The MWA will renew its investigation for inflow and infiltration in the area feeding the South Pierce Lift Station.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,

REPORT SUBMITTED BY: Heather Veal

CONTACTS:	Darryl Macy	OFFICE: 478-464-5673	CELL: 478-256-9363
	Mike Beard	OFFICE: 478-464-5694	CELL: 478-256-9382
	Heather Veal	OFFICE: 478-464-5669	CELL: 478-538-3238

CC MWA Email: Tony Rojas – Executive Director & President
Ray Shell – Executive Vice President of Field Operations
Mark Wyzalek – Laboratory & Environmental Compliance Director
Michel Wanna – Field Operations Director

CC Macon Telegraph: (Fax 478-744-4385)
Jennifer Burk (jburk@macon.com)

CC Other Email: Danny Tavakol – Macon-Bibb County
Carla D. Coley – Georgia DHR Macon
James Boecke – Macon-Bibb County Health Department
Altamaha Riverkeeper
WMAZ TV
WMGT