



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Gary Bechtel

### **MINOR SPILL REPORT TO EPD FAX 404 656-2453**

**EPD Watershed Protection Branch  
2 Martin Luther King, Jr. Drive  
Suite 1152  
Atlanta, GA 30334**

**DATE OF MINOR SPILL:** Saturday, January 21, 2017 3:00pm – 6:00pm

**REPORT SUBMITTED:** Tuesday, January 24, 2017

**LOCATION OF MINOR SPILL:** [2820 Pierce Drive S](#), MH ID 64565  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** The cause of this minor spill was hydraulic overload due to heavy rains in the MWA service area.

**ESTIMATED VOLUME DISCHARGED:** 3450 gallons  
*(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Bowman Branch

**SERVICE BASIN AFFECTED:** Corbin Avenue

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and affected area disinfected with lime.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Saturday, January 21, 2017

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** The MWA will renew its investigation for inflow and infiltration in the area feeding the South Pierce Lift Station.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,

**REPORT SUBMITTED BY:** Heather Veal

<b>CONTACTS:</b>	Darryl Macy	OFFICE: 478-464-5673	CELL: 478-256-9363
	Mike Beard	OFFICE: 478-464-5694	CELL: 478-256-9382
	Heather Veal	OFFICE: 478-464-5669	CELL: 478-538-3238

**CC MWA Email:** Tony Rojas – Executive Director & President  
Ray Shell – Executive Vice President of Field Operations  
Mark Wyzalek – Laboratory & Environmental Compliance Director  
Michel Wanna – Field Operations Director

**CC Macon Telegraph:** (Fax 478-744-4385)  
Jennifer Burk ([jburk@macon.com](mailto:jburk@macon.com))

**CC Other Email:** Danny Tavakol – Macon-Bibb County  
Carla D. Coley – Georgia DHR Macon  
James Boecke – Macon-Bibb County Health Department  
Altamaha Riverkeeper  
WMAZ TV  
WMGT