



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Gary Bechtel

### **MINOR SPILL REPORT TO EPD**

**DATE OF MINOR SPILL:** Sunday, January 22, 2017 5:45pm – 10:48pm

**REPORT SUBMITTED:** Tuesday, January 24, 2017

**LOCATION OF MINOR SPILL:** [2820 Pierce Drive S](#), MH ID 64565  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** The cause of this minor spill was hydraulic overload due to heavy rains in the MWA service area.

**ESTIMATED VOLUME DISCHARGED:** 6745 gallons  
*(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Bowman Branch

**SERVICE BASIN AFFECTED:** Corbin Avenue

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and affected area disinfected with lime.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Sunday, January 22, 2017

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** The MWA will renew its investigation for inflow and infiltration in the area feeding the South Pierce Lift Station.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,