



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

OVERFLOW REPORT

DATE OF OVERFLOW: Friday, March 3, 2017 9:15am – 10:15am

REPORT SUBMITTED: Tuesday, March 7, 2017

LOCATION OF OVERFLOW: 510 Pio Nono Avenue, MH ID 57915
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 1,200 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Riverside

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the sewage was washed back into the manhole.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Friday, March 3, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled to be cleaned with grease emulsifier and televised.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department