



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

MAJOR SPILL REPORT TO EPD

DATE OF MAJOR SPILL: Thursday, March 9, 2017 5:50pm – 8:30am 3/10/2017

REPORT SUBMITTED: Monday, March 13, 2017

LOCATION OF MAJOR SPILL: [4177 Forest Hill Terrace](#), MH ID 67585
(Please note that the address used is a reference for the location of the gravity main.)

CAUSE OF MAJOR SPILL: After the blockage was removed, it was determined that the cause of the major spill was grease and rags. There are commercial sources of grease upstream from this location and the information has been forwarded to the Grease Management Program Coordinator for follow up.

ESTIMATED VOLUME DISCHARGED: 17,600 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Sabbath Creek

SERVICE BASIN AFFECTED: Sabbath Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: The blockage was removed; sewage is no longer escaping.

SIGNS POSTED: Friday, March 10, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection List.

MONITORING INITIATED: Monitoring of upstream and downstream sites began on Monday, March 13, 2017.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department