



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

MINOR SPILL REPORT TO EPD FAX 404 656-2453

**EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334**

DATE OF MINOR SPILL: Friday, March 24, 2017 7:30pm – 10:30pm

REPORT SUBMITTED: Monday, March 27, 2017

LOCATION OF MINOR SPILL: [4288 Old Club Road East](#), MH ID 63870
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was grease and roots. There are commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 3,000 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area is being disinfected with lime.

SPILL STATUS: The blockage was removed; sewage is no longer escaping.

SIGNS POSTED: Friday, March 24, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection List and chemically treated for root control. This report will be forwarded to the Grease Management Program Coordinator for follow up.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WGXA (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,