



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Wednesday, April 12, 2017 7:00am – 1:15pm

REPORT SUBMITTED: Thursday, April 13, 2017

LOCATION OF MINOR SPILL: [Behind 1975 Deerwood Place](#), GM ID 18630
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 3,000 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Walnut Creek

SERVICE BASIN AFFECTED: Walnut Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area is being disinfected with lime.

SPILL STATUS: Sewage is no longer escaping; the sewer main has been repaired.

SIGNS POSTED: Wednesday, April 12, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: There sewer main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WGXA (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,