



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Friday, August 4, 2017 8:30pm – 8:50pm

REPORT SUBMITTED: Tuesday, August 8, 2017

LOCATION OF MINOR SPILL: [2820 Pierce Drive S](#), MH ID 64565
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: The cause of this minor spill was hydraulic overload due to heavy rains in the MWA service area.

ESTIMATED VOLUME DISCHARGED: 1700 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Bowman Branch

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and affected area disinfected with lime.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, August 8, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The MWA will renew its investigation for inflow and infiltration in the area feeding the South Pierce Lift Station.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,