



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, December 4, 2017 8:30am – 12:00pm

REPORT SUBMITTED: Friday, December 8, 2017

LOCATION OF OVERFLOW: [4064 Southview Drive](#), MH ID 52707
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: A large tree fell and broke the manhole and the sewer main.

ESTIMATED VOLUME DISCHARGED: 1,680 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Lower Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area disinfected with lime.

OVERFLOW STATUS: A by-pass pump was set up; sewage is no longer escaping.

SIGNS POSTED: Monday, December 4, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: A by-pass pump was set up at the site and a contractor has already begun the repair. Due to weather delays, the repair should be completed on Monday, December 11, 2017.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department