



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Gary Bechtel

**Revised: Please see cause and address. Should be Lake Valley Road.**

### **MINOR SPILL REPORT TO EPD**

**DATE OF MINOR SPILL:** Saturday, January 13, 2018 10:00am – 4:00pm

**REPORT SUBMITTED:** Wednesday, January 17, 2018

**LOCATION OF MINOR SPILL:** [1404 Lake Valley Road](#), MH ID 52535  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** After the blockage was removed, it was determined that the cause of this minor spill was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

**ESTIMATED VOLUME DISCHARGED:** 7,200 gallons  
*(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Ditch feeding Rocky Creek

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and the affected area is being disinfected with lime.

**SPILL STATUS:** The blockage was removed; sewage is no longer escaping.

**SIGNS POSTED:** Saturday, January 13, 2018

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** This line is scheduled to be cleaned with grease emulsifier and televised.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WGXA, WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,