



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Gary Bechtel

### **OVERFLOW REPORT**

**DATE OF OVERFLOW:** Monday, February 26, 2018 12:00am – 1:45am

**REPORT SUBMITTED:** Monday, February 26, 2018

**LOCATION OF OVERFLOW:** [1987 Wood Valley Road](#), MH ID 60037  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** After the blockage was removed, it was determined that the cause of this minor overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

**ESTIMATED VOLUME DISCHARGED:** 840 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Walnut Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and the affected area disinfected with lime.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Monday, February 26, 2018

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** This line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection List.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department