



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Larry Schlesinger

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Monday, April 23, 2018 7:50am – 11:00am

REPORT SUBMITTED: Thursday, April 26, 2018

LOCATION OF MINOR SPILL: [2840 Pierce Drive S](#), MH ID 82002
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: It was determined that the cause of this spill was hydraulic overload due to heavy rains in the MWA service area.

ESTIMATED VOLUME DISCHARGED: 5,200 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Bowman Branch

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, April 24, 2018

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The MWA Sewer Conveyance Department will continue to investigate the area for sources of inflow and infiltration into the sewer main.

MONITORING INITIATED: Monitoring of upstream and downstream was initiated on Tuesday, April 24, 2018 to determine the impact.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department