



R.A. "Tony" Rojas  
Executive Director & President

## Macon Water Authority

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## Members

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Larry Schlesinger

### OVERFLOW REPORT

**DATE OF OVERFLOW:** Tuesday, May 1, 2018 2:15pm – 3:00pm

**REPORT SUBMITTED:** Friday, May 04, 2018

**LOCATION OF OVERFLOW:** [Easement at Riverside Cemetery Lift Station](#), MH ID 66926  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF OVERFLOW:** It was determined that the cause of this minor overflow was a contractor pump malfunction.

**ESTIMATED VOLUME DISCHARGED:** 750 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**SERVICE BASIN AFFECTED:** Riverside

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and the sewage was washed back into the manhole.

**OVERFLOW STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Tuesday, May 1, 2018

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The contractor corrected the malfunction and sewage stopped escaping.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department