



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Larry Schlesinger

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, May 3, 2018 9:35am – 11:00am

REPORT SUBMITTED: Friday, May 04, 2018

LOCATION OF OVERFLOW: [262 Riley Avenue](#), MH ID 70876
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this minor overflow was grease and roots.

ESTIMATED VOLUME DISCHARGED: 420 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the sewage was washed back into the manhole.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, May 3, 2018

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This sewer main is scheduled to be cleaned with grease emulsifier and televised. It will also be chemically treated for root control.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department