



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Larry Schlesinger

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Tuesday, June 5, 2018 10:30am – 2:30pm

REPORT SUBMITTED: Wednesday, June 6, 2018

LOCATION OF MINOR SPILL: [2141 General Winship Drive](#), MH ID 71370
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: It was determined that the cause of this minor spill was a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 4,800 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Ocmulgee River

SERVICE BASIN AFFECTED: Riverside

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, June 5, 2018

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: Due to the location of this sewer main, the MWA had to hire a contractor to make this repair. The estimated completion date for this repair is Thursday, June 7th.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department