



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Larry Schlesinger

### **OVERFLOW REPORT**

**DATE OF OVERFLOW:** Tuesday, June 5, 2018 11:00pm – 1:30am 6/6/2018

**REPORT SUBMITTED:** Wednesday, June 6, 2018

**LOCATION OF OVERFLOW:** [2460 Pio Nono Ave](#), MH ID 52498  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** After the blockage was removed, it was determined that the cause of this minor overflow was grease. There are commercial sources of grease upstream from this location and this report will be forwarded to the Grease Management Program Coordinator for follow-up with those sources.

**ESTIMATED VOLUME DISCHARGED:** 1200 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and the sewage was washed back into the manhole.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Wednesday, June 6, 2018

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** This sewer main is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department