



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Larry Schlesinger

### **OVERFLOW REPORT**

**DATE OF OVERFLOW:** Saturday, December 8, 2018

**REPORT SUBMITTED:** Wednesday, December 12, 2018

**LOCATION OF OVERFLOW:** [1897 Allen Road](#), MH ID 74708  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** The cause of this minor overflow was a clogged by-pass pump.

**ESTIMATED VOLUME DISCHARGED:** 3500 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Echeconnee

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** The ponded sewage was vacuumed up and discharged back into the manahole. The affected area was disinfected with lime.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Monday, December 10, 2018

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The blockage was removed from the by-pass pump.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department