



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Larry Schlesinger

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, December 13, 2018 1:00pm – 3:00pm

REPORT SUBMITTED: Friday, December 14, 2018

LOCATION OF OVERFLOW: [6555 Champion Road](#), MH ID UNK
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: The cause of this minor overflow was a broken air release valve (ARV).

ESTIMATED VOLUME DISCHARGED: 3000 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Echeconnee

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: The ponded sewage was vacuumed up and discharged back into the manhole. The affected area was disinfected with lime.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, December 14, 2018

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The ARV connection was repaired and a new ARV will be installed.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department