



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Desmond D. Brown
Dwight Jones

Valerie Wynn
Bill Howell

Jess R. Shell
*Interim Executive
Director and
President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, December 20, 2021, 10:30am – 11:15am

REPORT SUBMITTED: Tuesday, December 21, 2021

LOCATION OF OVERFLOW: [2844 Napier Ave - MH ID: 56778](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 900 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Lower Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been disinfected with lime.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Monday, December 20, 2021

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders