



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Desmond D. Brown
Dwight Jones

Valerie Wynn
Bill Howell

Jess R. Shell
*Interim Executive
Director and
President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Tuesday, December 28, 2021, 9:10am – 10:16am

REPORT SUBMITTED: Tuesday, December 28, 2021

LOCATION OF MINOR SPILL: [2106 Old Clinton Rd - Sewer Main ID: 45440](#)
(Please note that the address used is a reference for the location of the sewer main.)

CAUSE OF MINOR SPILL: The cause of this major spill was due to a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 1,518 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Tributary to Walnut Creek

SERVICE BASIN AFFECTED: Walnut Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The debris has been removed from the affected area.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, December 28, 2021

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The broken sewer main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Mickie Sanders