



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Desmond D. Brown
Dwight Jones

Valerie Wynn
Bill Howell

Jess R. Shell
*Interim Executive
Director and
President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Sunday, January 2, 2022, 11:21am – 1:17pm

REPORT SUBMITTED: Monday, January 3, 2022

LOCATION OF MINOR SPILL: [475 Pierce Ave](#)
(Please note that the address used is a reference for the location of the unmapped manhole.)

CAUSE OF MINOR SPILL: The cause of this minor spill was grease and roots. There are no commercial sources of grease upstream of this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 946 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Creek feeding Bowman Branch

SERVICE BASIN AFFECTED: Corbin

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has been disinfected with lime.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Sunday, January 2, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The details of this overflow have been forwarded to our Grease Management team for further investigation. The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Mickie Sanders