



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Desmond D. Brown
Dwight Jones

Valerie Wynn
Bill Howell

Joey Leverette
*Executive Director
and President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, January 31, 2022, 10:15am – 11:30am

REPORT SUBMITTED: Tuesday, February 1, 2022

LOCATION OF OVERFLOW: [2964 Claridge Ct - MH ID: 70520](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 2,250 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Monday, January 31, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The line is scheduled to be cleaned grease emulsifier and televised. It has also been added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders