



**BOARD MEMBERS**

Samuel F. Hart, Sr.  
*Chairman*

Frank Patterson  
*Vice-Chairman*

Dr. Anissa Jones  
Desmond D. Brown  
Dwight Jones

Valerie Wynn  
Bill Howell

Joey Leverette  
*Executive Director  
and President*

790 Second Street  
P.O.Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

**MINOR SPILL REPORT TO EPD**

**DATE OF MINOR SPILL:** Friday, March 4, 2022, 1:57pm – 4:30pm

**REPORT SUBMITTED:** Tuesday, March 8, 2022

**LOCATION OF MINOR SPILL:** [4760 Carnoustie Ct – MH ID: 63777](#)  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF MINOR SPILL:** After the blockage was removed, it was determined that the cause of this overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

**ESTIMATED VOLUME DISCHARGED:** 3,519 gallons  
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**RECEIVING WATERS:** Ditch feeding Wolf Creek

**SERVICE BASIN AFFECTED:** Wolf Creek

**WRF SERVICE AREA NPDES PERMIT:** GA0024546

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**SPILL STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** Friday, March 4, 2022

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** This line is scheduled to be cleaned with grease emulsifier and televised. This location has also been added to the weekly Hot Spot Inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

**REPORT SUBMITTED BY:** Mickie Sanders