



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Desmond D. Brown
Dwight Jones

Valerie Wynn
Bill Howell

Joey Leverette
*Executive Director
and President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Friday, April 8, 2022, 9:30am – 11:45am

REPORT SUBMITTED: Tuesday, April 12, 2022

LOCATION OF OVERFLOW: [270 Vista Cir - MH ID: 70930](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was roots. Additionally, according to the National Weather Service, on April 5 and April 6, 2022, Macon-Bibb received a total of 5.38 inches of rain, hydraulically overloading the system with rain water.

ESTIMATED VOLUME DISCHARGED: 675 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Corbin

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Friday, April 8, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The line is scheduled to be cleaned and televised. It will also be chemically treated for root intrusion. It has been added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders