



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Shedrick Clark

Dwight Jones

Valerie Wynn
Bill Howell

Joey Leverette
*Executive Director
and President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Tuesday, April 26, 2022, 2:50pm – 5:00pm

REPORT SUBMITTED: Wednesday, April 27, 2022

LOCATION OF MINOR SPILL: [585 Tucker Rd – MH ID: 63684](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this overflow was debris and rags.

ESTIMATED VOLUME DISCHARGED: 1,800 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, April 26, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The line is scheduled to be cleaned and televised. It will also be added to the weekly Hot Spot Inspection list.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Mickie Sanders