



**BOARD MEMBERS**

Samuel F. Hart, Sr.  
*Chairman*

Frank Patterson  
*Vice-Chairman*

Dr. Anissa Jones  
Sheddrick Clark  
Dwight Jones

Valerie Wynn  
Bill Howell

Joey Leverette  
*Executive Director  
and President*

790 Second Street  
P.O.Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

**OVERFLOW REPORT**

**DATE OF OVERFLOW:** Wednesday, June 8, 2022, 3:30pm – 7:30pm

**REPORT SUBMITTED:** Thursday, June 9, 2022

**LOCATION OF OVERFLOW:** [2443 Broadway - MH ID: 60879](#)  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** After the blockage was removed, it was determined that the cause of this overflow was rags and roots.

**ESTIMATED VOLUME DISCHARGED:** 3,600 gallons  
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Bay Street

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**  
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Wednesday, June 8, 2022

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring. Additionally, it will be chemically treated for root intrusion.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department

**REPORT SUBMITTED BY:** Mickie Sanders