



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones
Shedrick Clark
Dwight Jones

Valerie Wynn
Bill Howell

Joey Leverette
*Executive Director
and President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, September 15, 2022, 9:24am – 12:00pm

REPORT SUBMITTED: Tuesday, September 20, 2022

LOCATION OF OVERFLOW: [2496 Charlene Ct - MH ID: 60802](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was rags.

ESTIMATED VOLUME DISCHARGED: 1,248 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Lower Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, September 15, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The details of this overflow have been forwarded to our grease management team for further investigation. The line is scheduled to be cleaned and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders