



BOARD MEMBERS

Samuel F. Hart, Sr.
Chairman

Frank Patterson
Vice-Chairman

Dr. Anissa Jones

Sheddrick Clark

Dwight Jones

Valerie Wynn

Bill Howell

Joey Leverette

*Executive Director
and President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Wednesday, September 28, 2022 at 4:00pm – Thursday, September 29, 2022 at 10:00am

REPORT SUBMITTED: Friday, September 30, 2022

LOCATION OF OVERFLOW: [670 Britton Way - MH ID: 81451](#)

(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was roots.

ESTIMATED VOLUME DISCHARGED: 3,240 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Tobesofkee

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, September 29, 2022

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The line is scheduled to be cleaned and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring. Additionally, this line is scheduled to be chemically treated for root intrusion.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders