



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Ed DeFore

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Wednesday, September 14, 2016 10:00am – 2:45pm

REPORT SUBMITTED: Friday, September 16, 2016

LOCATION OF MINOR SPILL: [Deadend of Jackson Springs Road West](#), GM ID 76031
(Please note that the address used is a reference for the location of the gravity main.)

CAUSE OF MINOR SPILL: The cause of this minor spill was a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 2,280 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ocmulgee River

SERVICE BASIN AFFECTED: Main Street

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris was removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: The line was repaired and sewage is no longer escaping.

SIGNS POSTED: Thursday, September 15, 2016

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The repair has been made to the sewer main.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department