



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Ed DeFore

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch

DATE OF MINOR SPILL: Monday, October 3, 2016 12:50pm – 2:20pm

REPORT SUBMITTED: Wednesday, October 5, 2016

LOCATION OF MINOR SPILL: [4237 Napier Avenue](#), MH ID 63884
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was roots.

ESTIMATED VOLUME DISCHARGED: 1,800 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris was removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Tuesday, October 4, 2016

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned and televised and will also be chemically treated for root control.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department