



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Ed DeFore

OVERFLOW REPORT

DATE OF OVERFLOW: Wednesday, October 19, 2016 11:00am – 1:30pm

REPORT SUBMITTED: Thursday, October 20, 2016

LOCATION OF OVERFLOW: [6767 Vinson Road](#), MH ID 82084
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was a plug left in the sewer main by the contractor who installed the main.

ESTIMATED VOLUME DISCHARGED: 300 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Echeconnee

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

OVERFLOW STATUS: The plug has been removed; sewage is no longer escaping.

SIGNS POSTED: Thursday, October 20, 2016

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This plug has been removed and the line is scheduled to be further televised.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department