



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Ed DeFore

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch

DATE OF MINOR SPILL: Friday, November 18, 2016 7:30am – 11:00am

REPORT SUBMITTED: Monday, November 21, 2016

LOCATION OF MINOR SPILL: [1469 Pitts Place](#), MH ID 59830
(Please note that the address used is a reference for the location of the gravity main.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 4,830 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Unnamed creek feeding the Ocmulgee River

SERVICE BASIN AFFECTED: Main Street

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris was removed from the area and the affected area has been disinfected with lime.

SPILL STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Monday, November 21, 2016

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection List.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department