



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Ed DeFore

OVERFLOW REPORT

DATE OF OVERFLOW: Thursday, January 5, 2017 1:32pm – 8:30pm

REPORT SUBMITTED: Friday, January 6, 2017

LOCATION OF OVERFLOW: [3279 Ohara Drive North, North Ohara Lift Station](#) , MH ID 52091
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: The cause of this overflow was a blockage in the force main caused by the inner parts of a broken gate valve.

ESTIMATED VOLUME DISCHARGED: 6,885 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Ohara

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

OVERFLOW STATUS: The station was put on by-pass; sewage stopped escaping.

SIGNS POSTED: Friday, January 6, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The blockage was removed from the line and the stem was placed back on the gate valve. Service was restored to the force main.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department