



R.A. "Tony" Rojas
Executive Director & President

Macon Water Authority

790 Second Street * P.O. Box 108
Macon, GA 31202-0108
(478) 464-5600 * FAX (478) 750-2007
Visit Us @ www.maconwater.org

Members

Samuel F. Hart, Sr., Chairman
Frank Patterson, Vice-Chairman
Javors J. Lucas
Dorothy "Dot" C. Black
Dwight Jones
Bert Bivins, III
Gary Bechtel

OVERFLOW REPORT

DATE OF OVERFLOW: Friday, January 20, 2017 4:43am – 5:10am

REPORT SUBMITTED: Friday, January 20, 2017

LOCATION OF OVERFLOW: [3398 Shady Road Plaza](#), Shady Rest Lift Station, MH ID 60453
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: The cause of this overflow was a pump failure at the lift station. The pumps became air locked and were not pumping to capacity.

ESTIMATED VOLUME DISCHARGED: 135 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Walnut Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area and the affected area has been disinfected with lime.

OVERFLOW STATUS: The lines were bled on the pumps and they resumed pumping; sewage stopped escaping.

SIGNS POSTED: Friday, January 20, 2017

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The pump issue was corrected and service was restored to the station.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department