



R.A. "Tony" Rojas  
*Executive Director & President*

## **Macon Water Authority**

790 Second Street \* P.O. Box 108  
Macon, GA 31202-0108  
(478) 464-5600 \* FAX (478) 750-2007  
Visit Us @ [www.maconwater.org](http://www.maconwater.org)

## **Members**

Samuel F. Hart, Sr., Chairman  
Frank Patterson, Vice-Chairman  
Javors J. Lucas  
Dorothy "Dot" C. Black  
Dwight Jones  
Bert Bivins, III  
Gary Bechtel

### **MINOR SPILL REPORT TO EPD**

**DATE OF MINOR SPILL:** Saturday, January 21, 2017 11:04am – 1:15pm

**REPORT SUBMITTED:** Monday, January 23, 2017

**LOCATION OF MINOR SPILL:** [3221 Broadway](#), MH ID 57899  
*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF MINOR SPILL:** After the blockage was removed, it was determined that the cause of this minor spill was grease. There are no commercial sources of grease upstream of this location and residential grease is not regulated.

**ESTIMATED VOLUME DISCHARGED:** 3275 gallons  
*(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**RECEIVING WATERS:** Ephemeral ditch with no known outlet

**SERVICE BASIN AFFECTED:** Bay Street

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area and the sewage was washed back into the manhole.

**SPILL STATUS:** The blockage was removed; sewage is no longer escaping.

**SIGNS POSTED:** Saturday, January 21, 2017

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** This line is scheduled to be cleaned with grease emulsifier and televised.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph, WMAZ (TV), WMGT (Radio), Macon – Bibb County Health Department, State of Georgia Health Department,