



BOARD MEMBERS

Gary Bechtel
Chairman

Dr. Anissa Jones
Vice-Chairman

Frank Patterson
Desmond Brown
Dwight Jones

Valerie Wynn
Bill Howell

Ron Shipman
Executive Director

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, May 15, 2023, 11:30am – 4:00pm

REPORT SUBMITTED: Wednesday, May 17, 2023

LOCATION OF OVERFLOW: [112 Westchester Dr – MH ID: 65363](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was roots.

ESTIMATED VOLUME DISCHARGED: 2,160 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Beaverdam Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Monday, May 15, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled to be cleaned and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring. Additionally, this line is scheduled to be chemically treated for root intrusion.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders