



BOARD MEMBERS

Gary Bechtel
Chairman

Dr. Anissa Jones
Vice-Chairman

Frank Patterson
Desmond Brown
Dwight Jones

Valerie Wynn
Bill Howell

Ron Shipman
Executive Director

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Monday, April 17, 2023, 7:30am – 9:00am

REPORT SUBMITTED: Thursday, April 20, 2023

LOCATION OF OVERFLOW: [2002 Bayswater Rd - MH ID: 60096](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 1,800 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Walnut Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed; sewage is no longer escaping.

SIGNS POSTED: Monday, April 17, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon – Bibb County Health Department

REPORT SUBMITTED BY: Mickie Sanders