



BOARD MEMBERS

Gary Bechtel
Chairman

Dr. Anissa Jones
Vice-Chairman

Frank Patterson
Desmond Brown
Dwight Jones

Valerie Wynn
Bill Howell

Ron Shipman
*Interim
Executive Director*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MAJOR SPILL REPORT TO EPD

DATE OF MAJOR SPILL: Friday, March 31, 2023, 7:00am – 10:25am

REPORT SUBMITTED: Tuesday, April 4, 2023

LOCATION OF MAJOR SPILL: [3040 Greenbriar Rd East – MH ID: 57511](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MAJOR SPILL: After the blockage was removed, it was determined that the cause of this overflow was debris.

ESTIMATED VOLUME DISCHARGED: 34,850 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Unnamed Ditch feeding Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, March 31, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned and televised. It has also been added to the weekly Hot Spot Inspection list for monitoring.

MONITORING INITIATED: Saturday, April 1, 2023

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Mickie Sanders