

**BOARD MEMBERS**

Gary Bechtel  
*Chairman*

Dr. Anissa Jones  
*Vice-Chairman*

Frank Patterson  
Desmond Brown  
Dwight Jones

Valerie Wynn  
Bill Howell

*Ron Shipman*  
*Executive Director*

790 Second Street  
P.O.Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

**OVERFLOW REPORT**

**DATE OF OVERFLOW:** Tuesday, June 6, 2023, 7:31am

**REPORT SUBMITTED:** Thursday, June 8, 2023

**LOCATION OF OVERFLOW:** [900 A St – MH ID: 57838](#)

*(Please note that the address used is a reference for the location of the manhole.)*

**CAUSE OF OVERFLOW:** A broken manhole was discovered at this location. Debris from the broken manhole and grease are the causes of this minor overflow. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

**ESTIMATED VOLUME DISCHARGED:** 2,000 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

**SERVICE BASIN AFFECTED:** Lower Rocky Creek

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**

The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**OVERFLOW STATUS:** The blockage has been removed; sewage is no longer escaping.

**SIGNS POSTED:** Tuesday, June 6, 2023

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The details of this overflow have been forwarded to our Grease Management team for further investigation. The line is scheduled to be cleaned with grease emulsifier and the manhole is scheduled to be repaired. This sewer main will be televised after the manhole repair has been completed. This location has been added to the weekly Hot Spot Inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon – Bibb County Health Department

**REPORT SUBMITTED BY:** Mickie Sanders