



BOARD MEMBERS

Gary Bechtel
Chairman

Dr. Anissa Jones
Vice-Chairman

Frank Patterson
Desmond Brown
Dwight Jones

Valerie Wynn
Bill Howell

Ron Shipman
Interim
Executive Director

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MINOR SPILL REPORT TO EPD

DATE OF MINOR SPILL: Wednesday, March 15, 2023, 7:48am – 10:55am

REPORT SUBMITTED: Thursday, March 17, 2023

LOCATION OF MINOR SPILL: [Rev JL Mills Sr Way – MH ID: 82146](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: The cause of this major spill was debris and bags.

ESTIMATED VOLUME DISCHARGED: 7,480 gallons
(Please note that this quantity is only a calculated estimation of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Storm ditch feeding Ocmulgee River

SERVICE BASIN AFFECTED: Bay Street

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Wednesday, March 15, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The line is scheduled to be cleaned and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon – Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Mickie Sanders