



BOARD MEMBERS

Gary Bechtel

Chairman

Dr. Anissa Jones

Vice-Chairman

Frank Patterson

Desmond Brown

Dwight Jones

Valerie Wynn

Bill Howell

Ron Shipman

*Executive Director
& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Tuesday, December 5, 2023, 10:30 pm – Wednesday, December 6, 2023, 12:15 am

REPORT SUBMITTED: Thursday, December 7, 2023

LOCATION OF OVERFLOW: [1230 Water Oak Court](#) - MH ID: 58072
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this overflow was grease. There is a commercial source of grease upstream from this location.

ESTIMATED VOLUME DISCHARGED: 2,100 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Lower Rocky Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: The blockage has been removed. Sewage is no longer escaping.

SIGNS POSTED: Wednesday, December 6, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The details of this minor overflow have been forwarded to our Grease Management team for further investigation. The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the weekly Hot Spot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones