



BOARD MEMBERS

Gary Bechtel

Chairman

Dr. Anissa Jones

Vice-Chairman

Frank Patterson

Dwight Jones

Valerie Wynn

Bill Howell

Desmond Brown

Ron Shipman

*Executive Director
& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Thursday, December 14, 2023, 12:56 pm – 4:30 pm

REPORT SUBMITTED: Friday, December 15, 2023

LOCATION OF MINOR SPILL: [1925 Flintwood Dr](#) - MH ID: 59902
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: The cause of this minor spill was due to a broken sewer main.

ESTIMATED VOLUME DISCHARGED: 4,280 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Ditch feeding Walnut Creek

SERVICE BASIN AFFECTED: Walnut Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Thursday, December 14, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The sewer main has been repaired. This line will also be added to the Hotspot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones