

BOARD MEMBERS Gary Bechtel Chairman

Dr. Anissa Jones Vice-Chairman Frank Patterson Dwight Jones Valerie Wynn Bill Howell

Ron Shipman
Executive Director

& President

Desmond Brown

790 Second Street P.0.Box 108 Macon, GA 31202 (478) 464-5600 Fax: (478) 750-2007 **MaconWater.org** MINOR SPILL REPORT TO EPD FAX 404-656-2453

EPD Watershed Protection Branch 2 Martin Luther King, Jr. Drive Suite 1152 Atlanta, GA 30334

DATE OF MINOR SPILL: Tuesday, November 28, 2023, 2:45 pm – 6:00 pm

REPORT SUBMITTED: Friday, December 1, 2023

LOCATION OF MINOR SPILL: 226 Sheraton Drive - MH ID: 65168

(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was grease. There is a commercial source of grease upstream from this location.

ESTIMATED VOLUME DISCHARGED: 4,485 gallons

(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Beaverdam Creek

SERVICE BASIN AFFECTED: Beaverdam Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, November 28, 2023

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The details of this minor spill have been forwarded to our Grease Management team for further investigation. The line is scheduled to be cleaned with grease emulsifier and televised. Additionally, this line will be added to the Hotspot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones