

**BOARD MEMBERS**

Gary Bechtel  
*Chairman*

Dr. Anissa Jones  
*Vice-Chairman*

Frank Patterson  
Desmond Brown  
Dwight Jones

Valerie Wynn  
Bill Howell

Ron Shipman  
*Executive Director  
& President*

790 Second Street  
P.O. Box 108  
Macon, GA 31202  
(478) 464-5600  
Fax: (478) 750-2007  
[MaconWater.org](http://MaconWater.org)

**OVERFLOW REPORT**

**DATE OF OVERFLOW:** Friday, January 5, 2024, 1:51 pm – 3:45 pm

**REPORT SUBMITTED:** Tuesday, January 9, 2024

**LOCATION OF OVERFLOW:** [6300 Moseley Dixon Road](#) – Lift Station ID: 68  
(Please note that the address used is a reference for the location of the force main.)

**CAUSE OF OVERFLOW:** The force main was damaged during an excavation by an independent contractor which caused sewage to escape from the pipe.

**ESTIMATED VOLUME DISCHARGED:** 2,000 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**SERVICE BASIN AFFECTED:** Tobesofkee

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

**OVERFLOW STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** January 5, 2024

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The force main has been repaired.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Bryan Jones