



BOARD MEMBERS

Gary Bechtel

Chairman

Dr. Anissa Jones

Vice-Chairman

Frank Patterson

Desmond Brown

Dwight Jones

Valerie Wynn

Bill Howell

Ron Shipman

*Executive Director
& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MAJOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MAJOR SPILL: Wednesday, February 14, 2024, 9:45 am – 12:45 pm

REPORT SUBMITTED: Monday, February 19, 2024

LOCATION OF MAJOR SPILL: [3040 Greenbriar Road East](#) - MH ID: 58215
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MAJOR SPILL: After the blockage was removed, it was determined that the causes of this spill were debris and sand.

ESTIMATED VOLUME DISCHARGED: 15,840 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Wednesday, February 14, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned and televised, we will continue to monitor this area.

MONITORING INITIATED: Friday, February 16, 2024

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones