



## OVERFLOW REPORT

### BOARD MEMBERS

Gary Bechtel

*Chairman*

Frank Patterson

*Vice-Chairman*

Dwight Jones

Valerie Wynn

Bill Howell

Desmond Brown

Ron Shipman

*Executive Director*

*and President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

[MaconWater.org](http://MaconWater.org)

**DATE OF OVERFLOW:** Monday, March 11, 2024, 11:00 am – 1:15 pm

**REPORT SUBMITTED:** Friday, March 15, 2024

**LOCATION OF OVERFLOW:** [150 Lake Terrace](#) – MH ID: 71132  
(Please note that the address used is a reference for the location of the manhole.)

**CAUSE OF OVERFLOW:** After the blockage was removed, it was determined that the cause of this minor overflow was grease. There are commercial sources of grease upstream from this location.

**ESTIMATED VOLUME DISCHARGED:** 2,700 gallons  
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

**SERVICE BASIN AFFECTED:** Corbin Avenue

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**  
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

**OVERFLOW STATUS:** Sewage is no longer escaping.

**SIGNS POSTED:** March 11, 2024

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW:** The details of this overflow have been forwarded to our Grease Management team for further investigation. This line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the Hotspot Inspection list for monitoring.

**MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** Macon Telegraph and Macon-Bibb County Health Department

**REPORT SUBMITTED BY:** Bryan Jones