



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Dwight Jones

Valerie Wynn

Bill Howell

Desmond Brown

Ron Shipman

*Executive Director
and President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Monday, March 18, 2024, 12:45 pm – 5:00 pm

REPORT SUBMITTED: Wednesday, March 20, 2024

LOCATION OF OVERFLOW: [2443 Broadway](#) – MH ID: 69772
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this minor overflow was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 765 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Bay Street

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: March 18, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The details of this overflow have been forwarded to our Grease Management team for further investigation. This line is scheduled to be cleaned with grease emulsifier and televised. It has also been added to the Hotspot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones