



BOARD MEMBERS

Gary Bechtel
Chairman

Dr. Anissa Jones
Vice-Chairman

Frank Patterson
Desmond Brown
Dwight Jones

Valerie Wynn
Bill Howell

Ron Shipman
*Executive Director
& President*

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

OVERFLOW REPORT

DATE OF OVERFLOW: Tuesday, February 27, 2024, 7:00 am – 1:35 pm

REPORT SUBMITTED: Friday, March 1, 2024

LOCATION OF OVERFLOW: [6138 Moseley Dixon Road](#)
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: The cause of this minor overflow was due to a defective air release valve.

ESTIMATED VOLUME DISCHARGED: 2,000 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

SERVICE BASIN AFFECTED: Tobesofkee Basin

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed and the area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, February 27, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The air release valve has been replaced and will be inspected semiannually.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones