

MAJOR SPILL REPORT TO EPD

BOARD MEMBERS
Gary Bechtel
Chairman
Frank Patterson
Vice-Chairman
Dwight Jones
Valerie Wynn
Bill Howell
Desmond Brown

Ron Shipman Executive Director and President

790 Second Street
P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

EPD Watershed Protection Branch 2 Martin Luther King, Jr. Drive Suite 1152 Atlanta, GA 30334

DATE OF MAJOR SPILL: Wednesday, March 6, 2024 & Thursday, March 7, 2024

REPORT SUBMITTED: Tuesday, March 12, 2024

LOCATION OF MAJOR SPILL: Outfall/Discharge to Ocmulgee River from the Rocky Creek Water Reclamation Facility at 4705 Mead Road

CAUSE OF MAJOR SPILL: High solids caused the WRF to exceed its daily threshold of Total Suspended Solids (TSS) as stated in the Authority's National Pollutant Discharge Elimination System Permit (NPDES).

MEASURED TSS EFFLUENT RESULT: The Georgia EPD requires Rocky Creek WRF to report as a Major Spill if the discharge to the waters of the State exceeds on any single day 67.5 mg/L for TSS.

The TSS for the dates reported were as follows:

3/6/2024 – 108 mg/L 3/7/2024 – 78 mg/L

VOLUME OF EFFLUENT DISCHARGED: 62.15 MG

RECEIVING WATERS: Ocmulgee River

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Aerators were immediately shut down to hold solids in the basins until the plant flows dropped, then were turned on slowly as plant conditions allowed to keep from overloading the clarifiers.

SPILL STATUS: Contained

SIGNS POSTED: March 5, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: Staff have been working to get the aerators back on. As many aerators are being run as possible across the plant to move the excess inventory through the treatment system and provide better solids breakdown, and they are slowed down or shut down only as necessary to hold solids in the aeration basins. We are making continual adjustments to the aeration basins and clarifiers, when possible, to try to manage the solids onsite without any more loss to the effluent. There are clarifier polymer feed systems set up on standby if needed to aid in solids settling. Wasting of excess solids is ongoing, and pressing is being done continuously if storage room is available. In addition, the MWA staff is still pursuing options for plant expansion to provide additional treatment and additional volume in the event of major storm events.



BOARD MEMBERS Gary Bechtel Chairman

Frank Patterson Vice-Chairman

Dwight Jones Valerie Wynn Bill Howell Desmond Brown

Ron Shipman Executive Director and President

790 Second Street
P.0.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007
MaconWater.org

MONITORING INITIATED: Monday, March 4, 2024

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones