



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel
Chairman

Frank Patterson
Vice-Chairman

Calder B. Clay III
Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman
Executive Director
& President

790 Second Street

P.O.Box 108
Macon, GA 31202
(478) 464-5600
Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Tuesday, July 23, 2024, 8:51 am – 11:57 am

REPORT SUBMITTED: Wednesday, July 24, 2024

LOCATION OF OVERFLOW: [679 Captain Kell Drive](#) – MH ID: 70647
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After the blockage was removed, it was determined that the cause of this minor overflow was due to root intrusion.

ESTIMATED VOLUME DISCHARGED: 1,488 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Corbin Avenue

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

The blockage has been cleared and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: July 23, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled to be cleaned and televised. It will also be added to the Hot Spot Inspection list for monitoring. Additionally, this line is scheduled to be chemically treated for root intrusion.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones